

Certificate of Conformity

By the product certificate number				No. 2622/0535-M5-CER
Issued to:				
License holder:	Huizhou Foryou Optoelect Building 6, B Area, No.1 Nor China		., LTD gjiang High-TechIndustry Park	k, Huizhou, Guangdong,
Trademark:	ADAYO			
Contract number:	802230			
It is certified that th	ne product:			
Type of generator:	Hybrid Inverter			
Models:		ED3600	ED4600	ED5000
Technical Data:	Rated Active Power	3600 W	4600 W	5000 W
	Rated Voltage		230 Vac	
	Rated Frequency		50 Hz	
	Firmware version		GA01.001-001-001	
	Number of phases		Single phase (L/N/PE)	
	Isolation transformer		No	

Is in compliance with standard:

EN 50549-1: 2019⁽¹⁾ "Requirements for generating plants to be connected in parallel with distribution networks" – Part 1: Connection to a LV Distribution Network - Generating Plants up to and including type B.

This certificate just covers PV inverters models certified below above-mentioned references to be installed in PV generating of type plants B to be connected to a LV distribution network.

The above-mentioned product is certified according to the standard EN 50549-1: 2019⁽¹⁾ and is valid to be installed in PV generating of type plants B to be connected to a LV distribution network. The relation between this European Standard with the relevant Article of COMMISSION REGULATION (EU) 2016/631 (NC RfG) is considered as it is indicated in the annex H of the standard EN 50549-1:2019.

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-53 based on the requirements of the UNE-EN ISO / IEC 17065.

This certificate is first issued on 23th June 2023. This certificate is valid until the 22nd December 2027.

Madrid, 23th June 2023

Daniel Arranz Muñiz Certification Manager



SGS Tecnos, S.A.U. C/ Trespaderne, 29 - 28042 Madrid This certificate is issued by SGS under its General Conditions for Product Certification at <u>www.sqs.com/terms_and_conditions</u>. The status and validity of the certificate can be checked scanning the QR code above included or through the following web <u>link</u>. This document cannot be reproduced partially

SGS





No. 2622/0535-M5-CER Page 1 of 1