

**TESTING FOR THE VERIFICATION OF COMPLIANCE OF  
PV INVERTER WITH :  
ENGINEERING RECOMMENDATION G99 ISSUE 1-  
AMENDMENT 8, 01 SEPTEMBER 2021,  
REQUIREMENTS FOR THE CONNECTION OF  
GENERATION EQUIPMENT IN PARALLEL WITH PUBLIC  
DISTRIBUTION NETWORKS ON OR AFTER 27 APRIL 2019**

Test Report Number .....: **GZES240300433001**

Type .....: Hybrid Inverter

Tested Model.....: **ED5000A**

Variant Models .....: ED4600A

**APPLICANT**

Hired by .....: Huizhou Foryou Optoelectronics Technology Co., Ltd

Address .....: Building 6, B Area, No.1 North Shangxia Road, Dongjiang High-Tech Industry Park, Huizhou, Guangdong, China

**TESTING LABORATORY**

Name .....: SGS-CSTC Standards Technical Services Co., Ltd  
Guangzhou Branch

Address .....: 198 Kezhu Road, Science City, Economic & Technology Development Area, Guangzhou, Guangdong, China



Conducted (tested) by .....: Doris Tao  
(Project Engineer)

*Doris Tao*

Approved by .....: Colin Chen  
(Technical Reviewer)

Date of issue.....: 2024-05-16

Number of pages .....: 96

**Important Note:**

- This document is issued by the Company under its General Conditions of service accessible at [http://www.sgs.com/terms\\_and\\_conditions.htm](http://www.sgs.com/terms_and_conditions.htm). Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.
- Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.
- Unless otherwise stated the results shown in this test report refer only to the sample(s) tested as received. **Information of derived or extension models of the range as provided by the applicant, (if any), is included in this report only for informative purposes.** The Company SGS shall not be liable for any incorrect results arising from unclear, erroneous, incomplete, misleading or false information provided by Client. This document cannot be reproduced except in full, without prior approval of the Company.

**Test Report Historical Revision:**

Test Report Version	Date	Resume
GZES24030043301	2024-05-16	<p>First issuance</p> <p><b>Remarks:</b> According to the declaration from the applicant, the only difference between the EUT (test samples in this report) and testing sample of report GZES220801676701, which was issued by SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou Branch as below:                      -Update applicant, manufacturer, trademark, models name, label, appearance and equipment type ect.</p> <p>After evaluation, no clause needs to retest. All test data originate from the report GZES220801676701, which was issued by SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou Branch.</p>

**INDEX**

<b>1</b>	<b>SCOPE .....</b>	<b>4</b>
<b>2</b>	<b>GENERAL INFORMATION.....</b>	<b>5</b>
2.1	Testing Period and Climatic conditions .....	5
2.2	Equipment under Testing .....	5
2.3	Manufacturer and Factory information .....	8
2.4	Test equipment list .....	8
2.5	Measurement uncertainty.....	9
2.6	Test set up of the different standard .....	10
2.7	Definitions.....	11
<b>3</b>	<b>RESUME OF TEST RESULTS.....</b>	<b>12</b>
<b>4</b>	<b>TEST RESULTS .....</b>	<b>13</b>
4.1	Operating Range .....	13
4.2	Power Quality .....	17
4.2.1	Harmonics .....	17
4.2.2	Voltage fluctuations and Flicker .....	19
4.2.3	DC Injection.....	22
4.2.4	Power Factor .....	23
4.3	Protection .....	25
4.3.1	Frequency tests.....	25
4.3.2	Voltage tests.....	46
4.3.3	Loss of Mains test .....	67
4.3.4	Loss of Mains Protection, Vector Shift Stability test and RoCoF Stability test .....	71
4.4	Limited Frequency Sensitive Mode - Overfrequency test .....	74
4.5	Re-connection timer .....	76
4.5.1	Voltage Reconnection Conditions .....	76
4.5.2	Frequency Reconnection Conditions .....	78
4.6	Fault level contribution .....	80
4.7	Self-Monitoring solid state switching.....	84
4.8	Wiring functional tests: .....	84
4.9	Logic interface (input port). .....	85
4.10	Cyber security .....	86
<b>5</b>	<b>PICTURES.....</b>	<b>87</b>
<b>6</b>	<b>ELECTRICAL SCHEME .....</b>	<b>96</b>

## 1 SCOPE

SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou Branch has been contract by Huizhou Foryou Optoelectronics Technology Co., Ltd, in order to perform the testing according the“ENGINEERING RECOMMENDATION G99 ISSUE 1-AMENDMENT 8, 1 September 2021, REQUIREMENTS FOR THE CONNECTION OF GENERATION EQUIPMENT IN PARALLEL WITH PUBLIC DISTRIBUTION NETWORKS ON OR AFTER 27 APRIL 2019”.

Note: This standard details connection process, technical and compliance requirements for Type A, Type B, Type C and Type D Power Generating Modules. The tests offered at this test report evaluate the EUT compliance with the requirements of **Type A** defined as below:

### Type A

A Power Generating Module with a Connection Point below 110 kV and a Registered Capacity of 0.8 kW or greater but less than 1 MW.

### Type B

A Power Generating Module with a Connection Point below 110 kV and Registered Capacity of 1 MW or greater but less than 10 MW.

### Type C

A Power Generating Module with a Connection Point below 110 kV and a Registered Capacity of 10 MW or greater but less than 50 MW.

### Type D

A Power Generating Module with a Connection Point at or greater than 110 kV, and/or with a Registered Capacity of 50 MW or greater.

**2 GENERAL INFORMATION**

**2.1 TESTING PERIOD AND CLIMATIC CONDITIONS**

The necessary testing has been performed along between the 16<sup>th</sup> of September of 2022 and 11<sup>th</sup> of April of 2023.

All the tests and checks have been performed at 25 ± 5°C, 96 kPa ± 10 kPa and 50% RH ± 10% RH).

**SITE TEST**

Name.....: **Dongguan BALUN Testing Technology Co., Ltd.**  
 Address.....: Room 104, 204, 205, Building 1, No. 6, Industrial South Road, Songshan Lake District, Dongguan, Guangdong, China.

**2.2 EQUIPMENT UNDER TESTING**

Apparatus type.....: Hybrid Inverter  
 Installation.....: Fixed installation  
 Manufacturer.....: **Huizhou Foryou Optoelectronics Technology Co., Ltd**  
 Address.....: Building 6, B Area, No.1 North Shangxia Road, Dongjiang High-Tech Industry Park, Huizhou, Guangdong, China  
 Trade mark.....: **ADAYO**  
 Model / Type reference.....: **ED5000A**  
 Serial Number.....: DN22222222  
 Software Version.....: GA01.001-001-001  
 Rated Characteristics.....: DC input: 150-500 V, Max. 2× 15 A  
 AC output: L/N/PE 230 V, 50 Hz, 21.7 A (23.9 A), 5000 W

Date of manufacturing: 2022

Test item particulars

Input.....: DC  
 Output.....: AC, L/N/PE  
 Class of protection against electric shock...: Class I  
 Degree of protection against moisture.....: IP 65  
 Type of connection to the main supply.....: Single phase – Fixed installation  
 Cooling group.....: Natural Cooling  
 Modular.....: No  
 Internal Transformer.....: No

Copy of marking plate (representative):

<b>Model Name:</b>	<b>ADAYO</b>	ED5000A
<b>PV Input:</b>		
PV max power :		7000W
PV max Voltage:		500Vdc
PV input voltage range		150-500Vdc
MPPT Voltage rang		120-430Vdc
Max input Current per string of tracker A/tracker B:		15A/15A
Starting Volatge:		150Vdc
<b>AC Output:</b>		
Norminal operating vltge:		230Vac
Max operating currnt:		23.9Aac
Norminal operating frequency:		50Hz
Maximum power:		5000W
Power Factor Range:		±0.8
<b>Back-Up Output:</b>		
Output Power:		4500W
Output Voltage:	230Vac ±2%, 50Hz(60Hz Optional)±0.2%	
<b>Battery:</b>		
Battery voltage range:		41.6V-58.5V
Maximum battery current(charge/discharge):		95A/100A
<b>General Data:</b>		
Dimension(H/W/D):		230*350*580mm
Weight:		25Kg
Transformer		Transformerless
Protect Class:		IP65
Cooling		Natural cooling
Interface:		USB/RS485/CAN
Display:		LCD
This Grid support interactive inverter complies with IEC 62109-1:2010,IEC 62109-2:2011 EN IEC 61000-6-1:2019 EN IEC 61000-6-3:2021 EN 50549-1:2019 VDE-AR-N 4105:2018 G99:2021 & G98:2021 NTs:2021-09 & UEN 217002:2020 CEI-021:2019		

**Note:**

1. The above markings are the minimum requirements required by the safety standard. For the final production samples, the additional markings which do not give rise to misunderstanding may be added.
2. Label is attached on the side surface of enclosure and visible after installation.
3. Labels of other models are as the same with **ED5000A**'s except the parameters of rating.
4. As declared by the applicant, the importer (and manufacturer, if it is different)'s name, registered trade name or registered trade mark and the postal address will be marked on the products before being place on the market. The contact details shall be in a language easily understood by end-users and market surveillance authorities.

**Equipment Under Testing:**- **ED5000A**

The variants models are:

- **ED4600A**

The models of ED5000A and ED4600A are identical on topological schematic circuit diagram and control solution codes except for input/output rating.

The variants models have been included in this test report without tests because the following features don't change regarding to the tested model:

- Same connection system and hardware topology
- Same control algorithm.
- Output power within  $1/\sqrt{10}$  and 2 times of the rated output power or the EUT or Modular inverters.
- Same Firmware Version.

Following table shows the full ratings of the all models referenced in this report, marked in **bold letters** the ones subjected to testing:

Model	ED4600A	ED5000A
<b>PV Input</b>		
Max. input voltage	500 Vdc	
Start-up operating voltage	150 Vdc	
Rated input voltage	360 Vdc	
MPPT operating voltage range	150-500 Vdc	
Full power MPPT voltage range	150-430 Vdc	
Max. input current	15 A/15 A	15 A/15 A
Max. short current	19.8 A/19.8 A	19.8 A/19.8 A
<b>Battery Input</b>		
operating voltage range	41.6V-58.5 Vdc	
Maximum battery charge current	95 A	95 A
Maximum battery discharge current)	100 A	100 A
<b>AC Output</b>		
Nominal grid voltage	L/N/PE, 230 V	
Nominal grid frequency	50 Hz	
Rated AC power	4600 W	5000 W
Max. AC power	5060 VA	5500 VA
Rated AC current	20.0 A	21.7 A
Max. AC current	22.0 A	23.9 A
Output power factor	1 default (adjustable+/-0.8)	
<b>General Data</b>		
Operating temperature range	-30 °C ~ +60 °C	
Protection degree	IP65	
Protective class	Class I	
Cooling method	Natural Cooling	
Topology	Transformerless	

The results obtained apply only to the particular sample tested that is the subject of the present test report. The most unfavorable result values of the verifications and tests performed are contained herein.

Throughout this report a point (comma) is used as the decimal separator.

**2.3 MANUFACTURER AND FACTORY INFORMATION**

Manufacturer Name .....: **Huizhou Foryou Optoelectronics Technology Co., Ltd**  
 Manufacturer Address .....: Building 6, B Area, No.1 North Shangxia Road, Dongjiang High-Tech Industry Park, Huizhou, Guangdong, China  
 Factory Name .....: **Shenzhen Donnergy Power Technology Co. Ltd .**  
 Factory Address.....: A305, Zongtai E-commerce Science and Innovation Park, Shiyang Street, Baoan District, Shenzhen, China.

**2.4 TEST EQUIPMENT LIST**

From	No.	Equipment Name	Trademark / Model No.	Equipment No.	Calibration Period
Balun	1	Power analyzer	ZLG/ PA6000H	BZ-DGD- L059	2022/10/13 to 2023/10/12
	2	Current probe	HIOKI/ CT6863-05	BZ-DGD- L026-1	2022/02/23 to 2023/02/22 2023/02/20 to 2024/02/19
	3	Current probe	HIOKI/ CT6863-05	BZ-DGD- L026-2	2022/02/23 to 2023/02/22 2023/02/20 to 2024/02/19
	4	Current probe	HIOKI/ CT6863-05	BZ-DGD- L026-4	2022/02/23 to 2023/02/22 2023/02/20 to 2024/02/19
	5	Voltage probe	CYBERTEK/ VP5200A	BZ-DGD-L241-1	2022/03/01 to 2023/02/28 2023/03/09 to 2024/03/08
	6	Voltage probe	CYBERTEK/ VP5200A	BZ-DGD-L241-2	2022/03/01 to 2023/02/28 2023/03/09 to 2024/03/08
	7	Voltage probe	CYBERTEK/ VP5200A	BZ-DGD-L241-3	2022/03/01 to 2023/02/28 2023/03/09 to 2024/03/08
	8	Temperature & Humidity meter	CEM/ DT-322	BZ-DGD-L005	2022/03/01 to 2023/02/28 2023/03/13 to 2024/03/12
	9	Digital oscilloscope	TEKTRONIX/ MS04054B	BZ-DGD-L064	2022/03/01 to 2023/02/28 2023/03/07 to 2024/03/06
	10	Power Analyzer	DEWETRON / TRIONet	BZ-DGD-L305	2022/08/18 to 2023/08/17
SGS	11	True RMS Multimeter	Fluke/187	GZE012-16	2022/05/21 to 2023/05/20



## 2.5 MEASUREMENT UNCERTAINTY

Associated uncertainties through measurements showed in this this report are the maximum allowable uncertainties.


Magnitude	Uncertainty
Voltage measurement	$\pm 1.5\%$
Current measurement	$\pm 2.0\%$
Frequency measurement	$\pm 0.2\%$
Time measurement	$\pm 0.2\%$
Power measurement	$\pm 2.5\%$
Phase Angle	$\pm 1^\circ$
Temperature	$\pm 3^\circ\text{C}$

Note1: Measurements uncertainties showed in this table are maximum allowable uncertainties. The measurement uncertainties associated with other parameters measured during the tests are in the laboratory at disposal of the petitioner.

Note2: Where the standard requires lower uncertainties that those in this table. Most restrictive uncertainty has been considered.

**2.6 TEST SET UP OF THE DIFFERENT STANDARD**

Below is the simplified construction of the test set up.



Different equipment has been used to take measures as it shows in chapter 2.3. Current and voltage clamps have been connected to the inverter input / output for all the tests. All the tests described in the following pages have used this specified test setup.

**The test bench used includes:**

EQUIPMENT	MARK / MODEL	RATED CHARACTERISTICS	OWNER / ID. CODE
AC source	KEWELL / KACM-75-33	60 kVA max. 45-65 Hz	BZ-DGD-L193
PV source	CHROMA / Chroma 6215011-1000s	15 kVA max.	BZ-DGD-L009
RLC load	QunLing / ACTL-3820	68 kW,68 kvar	BZ-DGD-L063

**2.7 DEFINITIONS**

EUT	Equipment Under Testing	Hz	Hertz
A	Ampere	V	Volt
VA <sub>r</sub>	Volt-Ampere reactive	W	Watt
EMC	Electromagnetic Compatibility	p.u	Per unit
U <sub>n</sub>	Nominal Voltage	P <sub>n</sub>	Nominal Active Power
I <sub>n</sub>	Nominal Current	Q <sub>n</sub>	Nominal Reactive Power
I <sub>a</sub>	Active Current	S <sub>n</sub>	Nominal Apparent Power
I <sub>r</sub>	Reactive Current	THD	Total Harmonic Distortion
I <sub>h</sub>	Harmonic Current	TDD	Total Demand Distortion
PWHD	Partial Weighted Harmonic Distortion	PLT	Severity of Flicker Long-Term
PST	Severity of Flicker Short-Term	d(t)	Variation of Voltage
d <sub>max</sub>	Maximum Absolute Value of Voltage Variation	OV	Over Voltage
UV	Under Voltage	OF	Over Frequency
		UF	Under Frequency

### 3 RESUME OF TEST RESULTS

#### INTERPRETATION KEYS

- Test object does meet the requirement ..... **P** Pass  
 Test object does not meet the requirement ..... **F** Fails  
 Test case does not apply to the test object ..... **N/A** Not applicable  
 To make a reference to a table or an annex. .... See additional sheet  
 To indicate that the test has not been performed ..... **N/P** Not performed

STANDAARD CLAUSE	STANDARD REQUIREMENTS		RESULT
	G99 Issue 1 Amendment 8 01 September 2021		
	TEST	REMARKS	
Annex A 2-3 (1)	Operating Range		P
A.7.1.5	Harmonics		P
A.7.1.4.3	Voltage fluctuations and Flicker		P
A.7.1.4.4	DC injection		P
A.7.1.4.2	Power Factor		P
A.7.1.2.3	Frequency tests		P
A.7.1.2.2	Voltage tests:		P
A.7.1.2.4	Loss of Mains test		P
A.7.1.2.6	Loss of Mains Protection, Vector Shift Stability test.		P
	Loss of Mains Protection, RoCoF Stability test		P
A.7.1.3	Limited Frequency Sensitive Mode – Over frequency test		P
Annex A 2-3 (10)	Re-connection timer.		P
A.7.1.5	Fault level contribution		P
A.7.1.7	Self-Monitoring solid state switching	No solid state switching devices	N/A
Para 15.2.1	Wiring functional tests		N/A
Annex A 2-3 (14)	Logic Interface (input port)		P
Annex A 2-3 (15)	Cyber security		P

## 4 TEST RESULTS

### 4.1 OPERATING RANGE

Two tests should be carried with the Power Generating Module operating at Registered Capacity and connected to a suitable test supply or grid simulation set. The power supplied by the primary source shall be kept stable within  $\pm 5\%$  of the apparent power value set for the entire duration of each test sequence.

Frequency, voltage and Active Power measurements at the output terminals of the Power Generating Module shall be recorded every second. The tests will verify that the Power Generating Module can operate within the required ranges for the specified period of time.

The Interface Protection shall be disabled during the tests.

The evaluation of this point has been made according to Annex A.7.2.2.

In case of a PV Power Park Module the PV primary source replaced by a DC source.

Test 1:

Voltage = 85% of nominal (195.5 V)

Frequency = 47 Hz

Power factor = 1

Period of test 20 s

Test 2:

Voltage = 85% of nominal (195.5 V)

Frequency = 47.5 Hz

Power factor = 1

Period of test 90 minutes

Test 3:

Voltage = 110% of nominal (253 V).

Frequency = 51.5 Hz

Power factor = 1

Period of test 90 minutes

Test 4:

Voltage = 110% of nominal (253 V).

Frequency = 52.0 Hz

Power factor = 1

Period of test 15 minutes

Test 5

Voltage = 100% of nominal (230 V),

Frequency = 50.0 Hz,



Power Factor = 1,

Period of test = 90 minutes


Test 6 RoCoF withstand

Confirm that the **Power Generating Module** is capable of staying connected to the **Distribution Network** and operate at rates of change of frequency up to 1 Hzs<sup>-1</sup> as measured over a period of 500 ms.


Test results are graphically shown in following pages.




Test 3




Test 4



Test 5



Test 6





## 4.2 POWER QUALITY

### 4.2.1 Harmonics

For Power Generating Modules of Registered Capacity of less than 75 A per phase (ie 50 kW) the test requirements are specified in Annex A.7.1.5. These tests should be carried out as specified in BS EN 61000-3-12 The results need to comply with the limits of Table 2 of BS EN 61000-3-12 for single phase equipment and Table 3 of BS EN 61000-3-12 for three phase equipment.

Power Generating Modules with emissions close to the limits laid down in BS EN 61000-3-12 may require the installation of a transformer between 2 and 4 times the rating of the Power Generating Module in order to accept the connection to a Distribution Network.


For Power Generating Modules of Registered Capacity of greater than 75 A per phase (ie 50 kW) the installation must be designed in accordance with EREC G5.

Measures have been repeated at 50%P<sub>n</sub> and 100%P<sub>n</sub>.


Following tables show the test results:

Power Generating Module rating per phase (rpp)		5	kVA		Harmonic % = Measured Value (A) x 23/rating per phase (kVA)	
Phase A						
Harmonic	At 45-55% of <b>Registered Capacity</b>		100% of <b>Registered Capacity</b>		Limit in BS EN 61000-3-12	
	Measured Value MV in Amps	(%)	Measured Value MV in Amps	(%)	1 Phase	3 Phase
2	0.012	0.056	0.179	0.822	8%	8%
3	0.091	0.417	0.271	1.249	21.6%	Not stated
4	0.004	0.017	0.044	0.203	4%	4%
5	0.076	0.348	0.129	0.592	10.7%	10.7%
6	0.004	0.016	0.025	0.115	2.67%	2.67%
7	0.065	0.297	0.082	0.377	7.2%	7.2%
8	0.002	0.009	0.018	0.085	2%	2%
9	0.058	0.266	0.059	0.270	3.8%	Not stated
10	0.002	0.010	0.015	0.071	1.6%	1.6%
11	0.048	0.222	0.053	0.244	3.1%	3.1%
12	0.002	0.009	0.013	0.060	1.33%	1.33%
13	0.032	0.148	0.048	0.219	2%	2%
THD	--	0.782	--	1.334	23%	13%
PWHD	--	1.281	--	1.936	23%	22%

**Current Harmonics**



**THD**



#### 4.2.2 Voltage fluctuations and Flicker

These tests should be undertaken in accordance with EREC G98 Annex A1 A.1.3.3 (Inverter connected) or Annex A2 A.2.3.3 (Synchronous).

The measurements of voltage fluctuations have been measured according to the standard, at 100 % of the nominal power value of the inverter.

The test impedance is recorded in the table below:

Test Impedance	R	0.24	$\Omega$	X	0.15	$\Omega$
Standard Impedance	R	0.24	$\Omega$	X	0.15	$\Omega$
Maximum Impedance	R	0.24	$\Omega$	X	0.15	$\Omega$

Starting operation and Stopping operation			
Pbin (%)	100%		
	Limit	Starting measured values	Stopping measured values
PST	$\leq 1$	0.052	0.047
PLT	$\leq 0.65$	0.050	0.050
dc	$\leq 3.30\%$	0.025	0.040
d(t)	$\leq 3.30\%$	0.000	0.000
dmax	4%	0.280	0.274

As it can be seen in the next screenshots, this test has two steps:

1. Starting operation
2. Stopping operation

All values are the most unfavorable of the two steps.

Starting operation and Stopping operation

100% Pn

Flicker Mode
Range Over

Flicker

U1
U2
U3
U4
U5
U6
U7

SCL
■

Line Filter
■

CH:

1

2

3

Count
2/2
Complete

Interval
00:00s/10:00s

Element
3

Volt Range
300 V/50Hz

Un (U1)
230.448V

Freq (U1)
49.994Hz

Dmin
0.30%

Element3
Judgement
Pass

Total
Judgement
Pass

(Element3)

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500 3.30%	1.00	0.65 N:2
No. 1	0.025 <span style="color: green;">Pass</span>	0.280 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.052 <span style="color: green;">Pass</span>	
2	0.040 <span style="color: green;">Pass</span>	0.274 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.047 <span style="color: green;">Pass</span>	
Result	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	0.050 <span style="color: green;">Pass</span>

ΣA(3P4W)

U1 300 V  
I1 500 mA  
Sync Src: U1  
Integral: Reset

U2 300 V  
I2 500 mA  
Sync Src: U1  
Integral: Reset

U3 300 V  
I3 500 mA  
Sync Src: U1  
Integral: Reset

Element 4

U4 1000 V  
I4 500 mA  
Sync Src: U1  
Integral: Reset

Element 5

U5 1000 V  
I5 10 V  
Sync Src: U1  
Integral: Reset

Element 6

U6 1000 V  
I6 10 V  
Sync Src: U1  
Integral: Reset

35%
1%
x1

2023-03-21
18:56:21

Running operation 2 hours		
Pbin (%)	100%	
	Limit	Measured values
PST	≤ 1	0.250
PLT	≤ 0.65	0.213
dc	≤ 3.30%	0.220
d(t)	≤ 3.30%	0.000
dmax	4%	0.431

As it can be seen in the next screenshots is running operation. The values took of Pst and Plt are the most unfavorable of the twelve steps.

**Running operation**  
**100% Pn**

Flicker Mode  
Flicker

Range Over

U1	U2	U3	U4	U5	U6	U7
I1	I2	I3	I4	I5	I6	I7

SCL  Line Filter

AVG  Freq Filter

PA\_00017.png

CH: 1 2 3

4 5 6 7

Count 12/12 Complete

Interval 00:00s/10:00s

Element 1

Volt Range 300 V/50Hz

Un (U1) 229.745V

Freq (U1) 50.000Hz

Dmin 0.15%

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500 3.30%	1.00	0.65 N:12
No. 1	0.173 <span style="color: green;">Pass</span>	0.387 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.197 <span style="color: green;">Pass</span>	
2	0.122 <span style="color: green;">Pass</span>	0.290 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.179 <span style="color: green;">Pass</span>	
3	0.203 <span style="color: green;">Pass</span>	0.394 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.167 <span style="color: green;">Pass</span>	
4	0.177 <span style="color: green;">Pass</span>	0.336 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.182 <span style="color: green;">Pass</span>	
5	0.220 <span style="color: green;">Pass</span>	0.395 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.208 <span style="color: green;">Pass</span>	
6	0.170 <span style="color: green;">Pass</span>	0.431 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.230 <span style="color: green;">Pass</span>	
7	0.153 <span style="color: green;">Pass</span>	0.351 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.250 <span style="color: green;">Pass</span>	
8	0.096 <span style="color: green;">Pass</span>	0.375 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.249 <span style="color: green;">Pass</span>	
9	0.140 <span style="color: green;">Pass</span>	0.384 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.235 <span style="color: green;">Pass</span>	
10	0.134 <span style="color: green;">Pass</span>	0.343 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.218 <span style="color: green;">Pass</span>	
11	0.122 <span style="color: green;">Pass</span>	0.279 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.205 <span style="color: green;">Pass</span>	
12	0.202 <span style="color: green;">Pass</span>	0.360 <span style="color: green;">Pass</span>	0.0 <span style="color: green;">Pass</span>	0.197 <span style="color: green;">Pass</span>	
Result	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	<span style="color: green;">Pass</span>	0.213 <span style="color: green;">Pass</span>

Update: 14029

Runtime: 8:02:17


2022-11-02 16:56:29

### 4.2.3 DC Injection

The tests should be carried out on a single Generating Unit. Tests are to be carried out at three defined power levels  $\pm 5\%$ . At 230 V a 6 kW three phase Inverter has a current output of 26A so DC limit is 65 mA. These tests should be undertaken in accordance with Annex A.7.1.4.4.

Following tables show the test results:

DC injection			
Test power level	10%	55%	100%
Recorded value in Amps	0.020	0.030	0.024
as % of rated AC current	0.092	0.138	0.110
Limit	0.25%	0.25%	0.25%




#### 4.2.4 Power Factor



The tests should be carried out on a single Power Generating Module. Tests are to be carried out at three voltage levels and at Registered Capacity. Voltage to be maintained within  $\pm 1.5\%$  of the stated level during the test. These tests should be undertaken in accordance with Annex A.7.1.4.2.

The following table shows the test results at required voltage levels:

Volatge	0.94 (p.u.)	1.00(p.u.)	1.10 (p.u.)
Measured Volatge value (V)	216.6	229.8	253.7
Measured Power Factor value (cos $\phi$ )	0.996	0.995	0.995
Power Factor Limit	>0.95	>0.95	>0.95

Test results are graphically shown below.







### 4.3 PROTECTION

#### 4.3.1 Frequency tests


These tests should be carried out in accordance with Annex A.7.1.2.3.

To establish a trip frequency, the test frequency should be applied in a slow ramp rate of less than 0.1 Hz/s, or if this is not possible in steps of 0.05 Hz for a duration that is longer than the trip time delay.



To establish the trip time, the test frequency should be applied starting from 0.3 Hz below or above the recorded trip frequency and should be changed to 0.3 Hz above or below the recorded trip frequency in a single step. For each trip setting five tests shall be carried out.



Function	Setting		Trip test (5 times)		"No trip tests"	
	Frequency	Time delay	Frequency (Hz)	Time delay (s)	Frequency /time	Confirm no trip
U/F stage 1	47.5 Hz	20 s	47.50	20.090	47.7 Hz / 30.00 s	Pass
			47.50	20.040		
			47.50	20.040		
			47.50	20.020		
			47.50	20.040		
U/F stage 2	47 Hz	0.5 s	47.00	0.535	47.2 Hz / 19.5 s	Pass
			47.00	0.550		
			47.00	0.540		
			47.00	0.550		
			47.00	0.525		
					46.8 Hz / 0.45 s	Pass
O/F stage 1	52 Hz	0.5 s	52.00	0.570	51.8 Hz / 120.00 s	Pass
			52.00	0.575		
			52.00	0.585		
			52.00	0.575		
			52.00	0.575		
					52.2 Hz / 0.45 s	Pass

Test results are graphically shown below.






U/F stage 1-2









U/F stage 1-4







U/F stage 2-1
















U/F stage 2-4





U/F stage 2-5




















No trip tests - 47.7Hz



No trip tests – 47.2Hz



M505104 Sat March 25 14:14:50 2023

**RIGOL** STOP H 4.00s 200kSa/s 10Mpts Measure STOP/RUN D -20.0s

光标

AX:	-27.52s
AY:	-8.166V
BX:	-7.16s
BY:	-28.83V
ΔX:	20.36s
ΔY:	-20.66V
1/ΔX:	49.11mHz



	最大值1	最小值1	峰峰值2	最大值2	有效值1	正占空比1
1	319.96V	-411.37V	74.489A	27.933A	229.02V	51.704%


1 1.00kV +1.16kV 2 100A -84.0A 3 1.00V +2.36V 4 10.0V +23.6V

0 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15



14:13

No trip tests – 46.8Hz





No trip tests – 52.2Hz



#### 4.3.2 Voltage tests

These tests should be carried out in accordance with Annex A.7.1.2.2.

To establish the certified trip voltage, the test voltage should be applied in steps of  $\pm 0.5\%$  of setting for a duration that is longer than the trip time delay.


To establish the certified trip time, the test voltage should be applied starting from  $\pm 1.8\%$  below the certified trip voltage in a step of at least  $\pm 0.5\%$  of setting for a duration that is longer than the trip time delay. For each trip setting five tests shall be carried out.



Following tables show the test results:

Function	Setting		Trip test		"No trip tests"	
	Voltage	Time delay	Voltage (V)	Time delay (s)	Voltage /time	Confirm no trip
U/V	184 V	2.5 s	183.18	2.535	188.0 V / 5.00 s	Pass
			183.45	2.520		
			183.74	2.525		
			183.22	2.530		
			183.89	2.535		
					180.0 V / 2.45s	Pass
O/V stage 1	262.2 V	1.0 s	261.81	1.055	258.2 V / 5.00 s	Pass
			261.31	1.060		
			261.59	1.055		
			261.92	1.050		
			261.51	1.055		
O/V stage 2	273.7 V	0.5 s	273.21	0.550	269.7 V / 0.95 s	Pass
			273.32	0.556		
			273.13	0.552		
			273.00	0.548		
			273.23	0.554		
					277.7 V / 0.45 s	Pass

Note for Voltage tests the Voltage required to trip is the setting  $\pm 3.45$  V. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting  $\pm 4$  V and for the relevant times as shown in the table above to ensure that the protection will not trip in error.



Test results are graphically shown in following pages.











U/V -3





U/V -4









O/V stage 1-1







O/V stage 1-2





O/V stage 1-3

































No trip tests – 188V






No trip tests – 180V











#### 4.3.3 Loss of Mains test

These tests should be carried out in accordance with BS EN 62116. Annex A.7.1.2.4.

The maximum trip time is 0.5 s.


Note for technologies which have a substantial shut down time this can be added to the 0.5 s in establishing that the trip occurred in less than 0.5 s. Maximum shut down time could therefore be up to 1.0 s for these technologies.

Following tables show the test results:


## ENA Engineering Recommendation G99 Issue 1 Amendment 8, 01 September 2021

Table: tested condition and trip time						P
No.	$P_{EUT}$ (% of EUT rating)	Reactive load (% of normal)	$P_{AC}$	$Q_{AC}$	Trip time (s)	Which load is selected to be adjusted (R or L)
Test condition A						
1	100	100	0	0	0.452	--
2	100	100	-5	-5	0.250	R/L
3	100	100	-5	0	0.236	R
4	100	100	-5	+5	0.247	R/L
5	100	100	0	-5	0.443	L
6	100	100	0	+5	0.253	L
7	100	100	+5	-5	0.239	R/L
8	100	100	+5	0	0.232	R
9	100	100	+5	+5	0.279	R/L
10	100	100	-10	+10	--	R/L
11	100	100	-5	+10	--	R/L
12	100	100	0	+10	--	L
13	100	100	+10	+10	--	R/L
14	100	100	+10	+5	--	R/L
15	100	100	+10	0	--	R
16	100	100	+10	-5	--	R/L
17	100	100	+10	-10	--	R/L
18	100	100	+5	-10	--	R/L
19	100	100	+5	+10	--	R/L
20	100	100	0	-10	--	L
21	100	100	-5	-10	--	R/L
22	100	100	-10	-10	--	R/L
23	100	100	-10	-5	--	R/L
24	100	100	-10	0	--	R
25	100	100	-10	+5	--	R/L
Test condition B						
1	66	66	0	0	0.251	--
2	66	66	0	-5	0.232	L
3	66	66	0	-4	0.237	L
4	66	66	0	-3	0.232	L
5	66	66	0	-2	0.243	L
6	66	66	0	-1	0.244	L
7	66	66	0	1	0.268	L
8	66	66	0	2	0.333	L
9	66	66	0	3	0.246	L
10	66	66	0	4	0.234	L
11	66	66	0	5	0.230	L
Test condition C						
1	33	33	0	0	0.249	--
2	33	33	0	-5	0.241	L
3	33	33	0	-4	0.243	L
4	33	33	0	-3	0.245	L
5	33	33	0	-2	0.238	L
6	33	33	0	-1	0.232	L
7	33	33	0	1	0.240	L
8	33	33	0	2	0.232	L
9	33	33	0	3	0.228	L
10	33	33	0	4	0.230	L
11	33	33	0	5	0.228	L


Test Condition A



Test Condition B



Test Condition C



#### **4.3.4 Loss of Mains Protection, Vector Shift Stability test and RoCoF Stability test**

This test should be carried out in accordance with Annex A.7.1.2.6.

Four tests are required to be carried out with all protection functions enabled including loss of mains. For each stability test the Micro-generator should not trip during the test.

For the step change test the Power Generating Module should be operated with a measurable output at the start frequency and then a vector shift should be applied by extending or reducing the time of a single cycle with subsequent cycles returning to the start frequency. The start frequency should then be maintained for a period of at least 10 s to complete the test. The Power Generating Module should not trip during this test.


For frequency drift tests the Power Generating Module should be operated with a measurable output at the start frequency and then the frequency changed in a ramp function at 0.95 Hz/s to the end frequency. On reaching the end frequency it should be maintained for a period of at least 10s. The Power Generating Module should not trip during this test.

Test results are graphically shown in following pages.


**Protection –Loss of Mains Protection, Vector Shift Stability test:** This test should be carried out in accordance with Annex A.7.1.2.6.

	Start Frequency	Change	Confirm no trip
Positive Vector Shift	49.5 Hz	+50 degrees	No Trip
Negative Vector Shift	50.5 Hz	- 50 degrees	No Trip

**Positive Vector Shift**



**Negative Vector Shift**







**Protection –Loss of Mains Protection, RoCoF Stability test:** This test should be carried out in accordance with Annex A.7.1.2.6.

Ramp range	Test frequency ramp:	Test Duration	Confirm no trip
49.0 Hz to 51.0 Hz	+0.95 Hzs <sup>-1</sup>	2.24 s	No Trip
51.0 Hz to 49.0 Hz	-0.95 Hzs <sup>-1</sup>	2.26 s	No Trip

+0.95 Hz/s:



-0.95 Hz/s:



#### 4.4 Limited Frequency Sensitive Mode - Overfrequency test

This test should be carried out in accordance with Annex A.7.1.3.

The test should be carried out above 80% Registered Capacity and repeated at 40-60% Registered Capacity using the specific threshold frequency of 50.4 Hz and Droop of 10%.

The Power Park Module should be tested at the following frequencies:


- Step a) 50.00 Hz  $\pm 0.01$  Hz
- Step b) 50.45 Hz  $\pm 0.05$  Hz
- Step c) 50.70 Hz  $\pm 0.10$  Hz
- Step d) 51.15 Hz  $\pm 0.05$  Hz
- Step e) 50.70 Hz  $\pm 0.10$  Hz
- Step f) 50.45 Hz  $\pm 0.05$  Hz
- Step g) 50.00 Hz  $\pm 0.01$  Hz

The frequency at each step should be maintained for at least one minute and the Active Power reduction in the form of a gradient determined and assessed for compliance with paragraph 11.2.3.

Test sequence at Registered Capacity 40% - 60%	Measured Active Power Output (W)	Frequency (Hz)	Primary Power Source	Active Power Gradient
Step a) 50.00 Hz $\pm 0.01$ Hz	5015.39	50.00	DC Souce	N/A
Step b) 50.45 Hz $\pm 0.05$ Hz	4977.62	50.45		13.2
Step c) 50.70 Hz $\pm 0.10$ Hz	4724.63	50.70		10.3
Step d) 51.15 Hz $\pm 0.05$ Hz	4270.93	51.15		10.1
Step e) 50.70 Hz $\pm 0.10$ Hz	4724.73	50.70		10.3
Step f) 50.45 Hz $\pm 0.05$ Hz	4978.67	50.45		13.6
Step g) 50.00 Hz $\pm 0.01$ Hz	5015.27	50.00		N/A


Test sequence at Registered Capacity 40% - 60%	Measured Active Power Output (W)	Frequency (Hz)	Primary Power Source	Active Power Gradient
Step a) 50.00 Hz $\pm 0.01$ Hz	2509.04	50.00	DC Souce	N/A
Step b) 50.45 Hz $\pm 0.05$ Hz	2474.33	50.43		14.4
Step c) 50.70 Hz $\pm 0.10$ Hz	2231.14	50.69		10.8
Step d) 51.15 Hz $\pm 0.05$ Hz	1780.84	51.13		10.3
Step e) 50.70 Hz $\pm 0.10$ Hz	2194.78	50.72		9.5
Step f) 50.45 Hz $\pm 0.05$ Hz	2459.57	50.46		10.1
Step g) 50.00 Hz $\pm 0.01$ Hz	2508.90	50.00		N/A

**Over-frequency curve (droop of 10 % at 100% Pn)**



Remark: Test for frequency threshold 50.4Hz with droop 10%, intentional delay is setting to 0s.

**Over-frequency curve (droop of 10 % at 50% Pn)**



Remark: Test for frequency threshold 50.4Hz with droop 10%, intentional delay is setting to 0s.

#### 4.5 Re-connection timer

Test should prove that the reconnection sequence starts after a minimum delay of 20 s for restoration of voltage and frequency to within the stage 1 settings of Table 10.1.

The evaluation of this point has been made according to Annex A.7.2.2.5.


##### 4.5.1 Voltage Reconnection Conditions

The following table detail tests performed


Test at	Time delay setting(s)	Measured delay(s)	Checks on no reconnection when voltage is brought to just outside stage 1 limits of table 1.	
UV	60	73.6	At 0.78 pu (180.0 V)	At 1.16 pu (266.2 V)
OV	60	74.0		
Confirmation that the Micro-generator does not re-connect.			Not reconnection	Not reconnection

Test results are graphically shown below.

Under voltage reconnection



Over voltage reconnection




#### 4.5.2 Frequency Reconnection Conditions

The following table detail tests performed


Test at	Time delay setting(s)	Measured delay(s)	Checks on no reconnection when frequency is brought to just outside stage 1 limits of table 1.	
UF	60	78.8	At 47.4Hz	At 52.1Hz
OF	20	78.4		
Confirmation that the Micro-generator does not re-connect.			Not reconnection	Not reconnection

Test results are graphically shown below.

Under frequency reconnection



Over frequency reconnection





#### 4.6 Fault level contribution

These tests shall be carried out in accordance with EREC G99 Annex A.7.1.5.


They have been performed different short circuit tests that are detailed in the table and pictures below.

Short circuit current		
L-N		
Time after fault	Volts(V)	Amps(A)
20ms	0.428	0.007
100ms	0.291	0.011
250ms	0.168	0.006
500ms	0.104	0.005
Time to trip	0.004	In seconds







Time after 250ms fault



Time after 500ms fault





#### **4.7 SELF-MONITORING SOLID STATE SWITCHING**

It has been verified that in the event of the solid state switching device failing to disconnect the Power Park Module, the voltage on the output side of the switching device is reduced to a value below 50 volts within 0.5 s.

The evaluation of this point has been made according to Annex A.7.1.7.

This test does not apply because in the inverter there are not solid-state switching devices.

#### **4.8 WIRING FUNCTIONAL TESTS:**

Where Type Tested components are wired together on site, ie not using specifically designed plugs and sockets for the purpose, it will be necessary to prove that all wiring has been correctly terminated by proving the functions which rely on the wiring. The Generator will submit to the DNO for agreement a schedule of the wiring connections to be made, the functions that they enable, and the tests to prove them. Satisfactory completion of the agreed tests will enable the Power Generating Modules to attain or retain Type Tested status.

This test does not apply because connectors were designed error-proof connectors.


#### 4.9 LOGIC INTERFACE (INPUT PORT).

Confirm that an input port is provided and can be used to shut down the module.

The evaluation of this point has been made according to Clause 11.1.3 of the standard.

Power Generating Modules connected to the DNO's Distribution Network shall be equipped with a logic interface (input port) in order to cease Active Power output within 5 s following an instruction being received at the input port.

Test results are graphically shown as below.



#### 4.10 CYBER SECURITY

Confirm that the **Power Generating Module** has been designed to comply with cyber security requirements, as detailed in 9.1.7.

The Manufacturer of the Micro-generator has provided a statement describing how the Micro-generator has been designed to comply with cyber security requirements in 9.1.7.

Additional comments.

The DNO logic interface will take the form of a simple binary output that can be operated by the switch. When the switch is turned off the Power Generating Module can operate normally. When the switch is turned on the Power Generating Module will reduce its Active Power to zero within 5 s. The signal from the Power Generating Module that is being switched is DC (maximum value 3.3Vdc)

5 PICTURES

Front view




Back Side



Connection interface



Top Side







External grounding




General Internal view of inverter



**Front of main power board**



**Back of main power board**



**Front of Bus capacitance board**




**Back of Bus capacitance board**




Front of capacitance board




Back of capacitance board




Front of control board




Back of control board



Front of display board




Back of control board



## Serial Number



6 ELECTRICAL SCHEME



-----END OF REPORT-----