

**TESTING FOR THE VERIFICATION OF
COMPLIANCE OF MICROINVERTER WITH :
VDE 0126-1-1 +VFR:2013 + VFR:2014 and VFR: 2019:
AUTOMATIC DISCONNECTION DEVICE BETWEEN
A GENERATOR AND THE PUBLIC LOW-VOLTAGE
GRID. 2013**

Protocol PE.T-LE-62

Test Report Number : GZES240300433301
Equipment : Microinverter
Trademark : **ADAYO**
Tested Model : ID800D
Variant Models : ID400A, ID400D, ID400M, ID600A, ID600D, ID600M, ID800A,
ID800M

APPLICANT

Name : Huizhou Foryou Optoelectronics Technology Co., Ltd
Address : Building 6, B Area, No.1 North Shangxia Road, Dongjiang High-
Tech Industry Park, Huizhou, Guangdong, China

TESTING LABORATORY

Name : SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou
Branch
Address : 198 Kezhu Road, Science City, Economic & Technology
Development Area, Guangzhou, Guangdong, China

Conducted (tested) by : Doris Tao *Doris Tao*
(Project Engineer)

Reviewed & Approved by : Colin Chen *Chen*
(Technical Reviewer)

Date of issue : 2024/04/22

Number of pages : 68



Important Note:

- This document is issued by the Company under its General Conditions of service accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.
- Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.
- Unless otherwise stated the results shown in this test report refer only to the sample(s) tested as received. **Information of derived or extension models of the range as provided by the applicant, (if any), is included in this report only for informative purposes.** The Company SGS shall not be liable for any incorrect results arising from unclear, erroneous, incomplete, misleading or false information provided by Client. This document cannot be reproduced except in full, without prior approval of the Company.

Test Report Historical Revision:

Test Report Version	Date	Resume
GZES240300433301	2024/04/22	<p>First issuance.</p> <p>Remarks: According to the declaration from the applicant, the only difference between the EUT (test samples in this report) and testing sample of report GZES240100061701, which was issued by SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou Branch as below: -Update applicant, manufacturer, trademark, models name, label, appearance and equipment type ect.</p> <p>After evaluation, no clause needs to retest. All test data originate from the report GZES240100061701, which was issued by SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou Branch.</p>

INDEX

1	SCOPE.....	4
2	GENERAL INFORMATION	5
2.1	Testing Period and Climatic conditions	5
2.2	Equipment under Testing	5
2.3	Manufacturer and Factory information	9
2.4	Test Equipment List	10
2.5	Measurement Uncertainty	10
2.6	Test set up of the different standard	11
2.7	Definitions	12
3	RESUME OF TEST RESULTS	13
4	TEST RESULTS	14
4.1	Functional safety.....	14
4.2	Connection and reconnection conditions	15
4.3	Voltage monitoring	18
4.4	Frequency monitoring	28
4.5	DC current monitoring	35
4.6	Anti islanding protection	36
4.6.1	Test A	36
4.6.2	Test B	43
4.6.3	Test C.....	50
4.7	Marking.....	57
4.8	Residual Current	57
4.9	Table: Active power output feed-in at overfrequency.....	58
5	PICTURES	62
6	ELECTRICAL SCHEMES.....	68

1 SCOPE

SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou Branch has been contract by Huizhou Foryou Optoelectronics Technology Co., Ltd to perform the testing according the VDE 0126-1-1:2013 +VFR:2013 + VFR:2014 and VFR: 2019: Automatic disconnection device between a generator and the public low-voltage grid.

The following standard are covered with testing:

- Enedis-PRO-RES_10E:26/06/2020 Description et étude des protections de découplage pour le raccordement des Installations de Production raccordées au Réseau Public de Distribution

2 GENERAL INFORMATION

2.1 Testing Period and Climatic conditions


The necessary testing has been performed between the 27th of January and the 13rd of March of 2024.

All the tests and checks have been performed in accordance with the reference Standard (the tests are done at 25 ± 5°C, 96 kPa ± 10 kPa and 65% RH ± 10% RH).

SITE TEST


Name : Dongguan BALUN Testing Technology Co., Ltd.
 Address : Room 104, 204, 205, Building 1, No. 6, Industrial South Road, Songshan Lake District, Dongguan, Guangdong, China.

2.2 Equipment under Testing

Apparatus type : Microinverter (Single phase)
 Installation : Fixed(permanent connection)
 Manufacturer : Huizhou Foryou Optoelectronics Technology Co., Ltd
 Address : Building 6, B Area, No.1 North Shangxia Road, Dongjiang High-Tech Industry Park, Huizhou, Guangdong, China
 Trade mark : 
 Model / Type reference : ID800D
 Serial Number..... : WWA2344068
 Software Version : DH01.001-000-000
 Rated Characteristics..... : DC Input: MPPT 33~55 Vdc (60 Vdc max.),
 14 A*2 Maximum.
 AC Output: 230 Vac, 50 Hz, 3.48 A, 800 W.

Date of manufacturing: 2023

Input : DC
 Output : AC
 Class of protection against electric shock... : Class I
 Degree of protection against moisture..... : IP 67
 Type of connection to the main supply : TN
 Cooling group : Natural Cooling
 Modular : No
 Internal Transformer : Yes

Copy of marking plate(representative):**Note:**

1. The above markings are the minimum requirements required by the safety standard. For the final production samples, the additional markings which do not give rise to misunderstanding may be added.
2. Label is attached on the back of enclosure and visible after installation.
3. Labels of other models are as the same with ID800D's except the parameters of rating.

Equipment under testing:

- ID800D

The variants models are:

- ID800A
- ID800M
- ID600A
- ID600D
- ID600M
- ID400A
- ID400D
- ID400M

The variant models have been included in this test report without tests because the following features don't change regarding to the tested model:

- Same connection system and hardware topology.
- Same control algorithm.
- Output power within $1/\sqrt{10}$ and 2 times of the rated output power of the EUT or Modular inverters.
- Same Firmware Version.

The models of ID400A, ID400D, ID400M, ID600A, ID600D, ID600M, ID800A, ID800D and ID800M are identical on topological schematic circuit diagram and control solution codes.

The results obtained apply only to the particular sample tested that is the subject of the present test report.

The most unfavorable result values of the verifications and tests performed are contained herein.

Throughout this report a point (~~comma~~) is used as the decimal separator.

Following table shows the full ratings of all the models referenced in this report, marked in **bold letters** is the one subjected to testing:

Model	ID400A ID400M ID400D	ID600A ID600M ID600D	ID800A ID800M ID800D
PV Input			
Number of MPPT Trackers	2		
Max. Input Voltage	60 Vdc		
Start-up Operating Voltage	30 Vdc		
Operating Voltage Range	16V-60 Vdc		
MPPT Voltage Range	33V-55 Vdc		
Max. Input Current	7 A * 2	12 A * 2	14 A * 2
Max. Short Current	15 A * 2	20 A * 2	25 A * 2
AC Output			
Nominal Grid Voltage	L/N/PE, 230Vac		
Nominal Grid Frequency	50 Hz		
Rated AC Power	400 W	600 W	800 W
Max. AC Power	400 VA	600 VA	800 VA
Rated AC Current	1.74 A	2.60 A	3.48 A
Output Power Factor	>0.99		
General Data			
Operating temperature range	-40 °C ~ +65 °C		
Protection degree	IP67		
Protective class	Class I		
Altitude	Max. 2000m		
Cooling method	Natural Cooling		
Topology	Transformer		

2.3 Manufacturer and Factory information

Manufacturer Name: Huizhou Foryou Optoelectronics Technology Co., Ltd
Manufacturer Address.....: Building 6, B Area, No.1 North Shangxia Road,
Dongjiang High-Tech Industry Park, Huizhou,
Guangdong, China

Factory Name: Shenzhen Donnergy Technology Co., Ltd
Factory Address.....: 6F Building 8, Xianan Third Industrial Zone, Shangcun
Community, Gongming Street, Guangming District,
Shenzhen, China

2.4 Test Equipment List

From	No.	Equipment Name	Trademark / Model No.	Equipment No.	Calibration Period
LBALUN	1	Power analyzer	ZLG/ PA6000H	BZ-DGD-L059	2023/09/20 to 2024/09/19
	2	Power analyzer	DEWETRON/ TRIONet	BZ-DGW-L048-1	2023/10/31 to 2024/10/30
	3	Oscilloscope	RIGOL/ MSO5104	DNG2021017	2023/06/15 to 2024/06/14
	4	Current Clamp	HIOKI/ CT6863-05	BZ-DGD-L026-1	2024/01/23 to 2025/01/22
	5	Current Clamp	HIOKI/ CT6863-05	BZ-DGD-L026-2	2024/01/23 to 2025/01/22
	6	Current Clamp	HIOKI/ CT6863-05	BZ-DGD-L026-3	2024/01/23 to 2025/01/22
	7	Current Clamp	CYBERTEK/ CP8150A	BZ-DGD-L067	2024/01/23 to 2025/01/22
	8	Differential probe	CYBERTEK/ VP5200A	BZ-DGD-L241-1	2024/01/23 to 2025/01/22
	9	Oscilloscope probe	Tektronix/ TPP0500	BZ-DGD-L028-1	2024/01/23 to 2025/01/22
	10	Temperature & Humidity meter	CEM/ DT-322	BZ-DGD-L270	2023/09/13 to 2024/09/12
SGS	11	True RMS Multimeter	FLUKE / 15B	GZE012-43	2023/10/29 to 2024/10/28

2.5 Measurement Uncertainty

Associated uncertainties through measurements showed in this this report are the maximum allowable uncertainties.


Magnitude	Uncertainty
Voltage measurement	±1.5 %
Current measurement	±2.0 %
Frequency measurement	±0.2 %
Time measurement	±0.2 %
Power measurement	±2.5 %
Phase Angle	±1 °
Temperature	±3 °C

Note1: Measurements uncertainties showed in this table are maximum allowable uncertainties. The measurement uncertainties associated with other parameters measured during the tests are in the laboratory at disposal of the petitioner.

Note2: Where the standard requires lower uncertainties that those in this table. Most restrictive uncertainty has been considered.

2.6 Test set up of the different standard

Below is the simplified construction of the test set up.



Different equipment has been used to take measures as it shows in chapter 2.4. Current and voltage clamps have been connected to the inverter input / output for all the tests. All the tests described in the following pages have used this specified test setup.

The test bench used includes:

EQUIPMENT	MARK / MODEL	RATED CHARACTERISTICS	OWNER / ID. CODE
AC source	WAGO / WLPA-33030kVA	30 kVA max. 45-65 Hz	BZ-DGD-L272
DC source	Chroma / 6215011-1000S	15 kVA max.	BZ-DGD-L009
RLC load	Qunlin / ACLT-3820	68 kW, 68 kVAr	BZ-DGD-L063

2.7 Definitions

In	Nominal Current	P	Power
p.u	Per unit	I	Current
Pn	Nominal Power	M	Change for real power
Sn	Apparent Power	N	Change for reactive power
PGU	Power Generation Unit	F	Frequency
Pst	Short-term flicker strength	Q _f	Quality factor
Plt	Long-term flicker strength	NS	Network and System
C _{ψK}	Flicker coefficient for continuous operation	Un	Nominal Voltage
S _r	Apparent Power Rated	PWHD	Partial weight harmonic distortion
S _k	Short-circuit Apparent Power	THD	Total harmonic distortion
K _{imax}	Maximum switching current factor	Z _{test}	Test circuit impedance at which the emission test
Z _{ref}	The reference impedance	EUT	Equipment under test

3 RESUME OF TEST RESULTS

INTERPRETATION KEYS

- Test object does meet the requirement **P** Pass
- Test object does not meet the requirement **F** Fails
- Test case does not apply to the test object..... **N/A** Not applicable
- To make a reference to a table or an annex. See additional sheet
- To indicate that the test has not been performed..... **N/P** Not performed

CHAPTER OF THE STANDARD, DESCRIPTION AND VERIFICATION			
4	Requirements		
4.1	Functional safety		P
4.2	Reconnection		P
4.3.1	Voltage monitoring -20%		P
4.3.2	Voltage monitoring +10%		P
4.3.3	Voltage monitoring +15%		P
4.4.1	Frequency monitoring: 51.5Hz		P
4.4.2	Frequency monitoring: 47.5Hz		P
4.5	DC current monitoring		N/A
4.6	Anti-Islanding Protection		P
4.7	Marking		P
4.8	Residual Current		P
4.9	Table: Active poewr output feed-in at overfrequency		P

4 TEST RESULTS

4.1 FUNCTIONAL SAFETY

The security as defined in 4.3 to 4.8 of the standard must turn in an error state and display this error condition.

Testing of the single-fault tolerance and fault detection with subsequent disconnection is carried out by fault simulation, if necessary with additional fault tests.

It must be checked that a single fault does not lead to loss of the safety function.

The results are offered in the table below:

Based on an analysis of the products circuits, capacitors, diodes, solid –state devices and similar component were subjected to shorting or opening while the product was energized at rated voltage and under load (if grid connected it shall be tied to a simulated grid). Evidence of malfunction as specified above shall be noted and recorder.


In addition the utility – interactive inverter was monitored for backfeed current that flows from the simulated utility source into the photovoltaic array as a result of a faulted components. This was done by monitoring the dc current to the dc supply input with the dc source off and the simulated circuit operating.

The compliances with these requirements are stated in section 4.4 on pages 51 to 53 of the following test report:



- IEC 62109-1:2010: Test Report n° GZES231202137901 on Dec. 18, 2023 which issued by SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou Branch.


4.2 CONNECTION AND RECONNECTION CONDITIONS

The power generation system shall be connected to the network only if both voltage and frequency are within the tolerance range according to article 4.2. It is shown that the active power don't exceed the gradient of 10 % of the active power per minute (green line).



Reconnection delay time limit: 60 s	Reconnection time measured: 69.4 s
Gradient (ΔP) desired (%P _n /min) limit: 10%	Gradient measured (%P _n /min): 9.0%





4.3 VOLTAGE MONITORING

According to article 4.3 the NS protection should disconnect the power generation system from the net in the event of inadmissible voltage values. This point of the standard redirect to the point 6.5 of the VDE AR-N 4105:2011.

- a) For measurement of the phase to phase voltages the phase angle must be turned so that one phase to phase voltage reaches the limit value, whereby the phase to neutral voltages for testing the overvoltage are set to 110 % U_n and for undervoltage to 90 % U_n .
- b) For the measurement of the phase to neutral voltage, one phase to neutral voltage should be changed, whereby both other phase to neutral voltages are maintained at the nominal voltage. This test must be carried out separately for each phase.

To measure the response time, a voltage changes of:

- Nominal voltage to 118 % U_n for overvoltage and
- Nominal voltage to 77 % U_n for undervoltage

is carried out.



All tests for verification of the disconnection values and times must be carried out three times.

The results are offered in the table below:



Disconnection time measured					
Protective function	Voltage changes	Disconnection time limits	Test 1	Test 2	Test 3
Rise-in-voltage protection ($U >>$)	100% U_n to 118% U_n	< 200 ms	35 ms	43 ms	34 ms
Voltage drop protection ($U <$)	100% U_n to 77% U_n	< 200 ms	144 ms	144 ms	142 ms

In the picture below are offered waveforms and graphically the results of the test.



Nominal voltage to 118 % Un for overvoltage - Test 1





Nominal voltage to 118 % Un for overvoltage - Test 2





Nominal voltage to 118 % Un for overvoltage - Test 3





Nominal voltage to 77 % Un for undervoltage - Test 1



Nominal voltage to 77 % Un for undervoltage - Test 2



Nominal voltage to 77 % Un for undervoltage - Test 3



The rise-in voltage protection $U>$ test is carried out as follows:

- a) The voltage is set to 100 % U_n and maintained for 600 s. The voltage is then set to 112 % U_n . Disconnection must be effected within 600 seconds.



NOTE This test serves to verify the measuring accuracy and the maximum set time.


- b) The voltage is set for 600 s to U_n , then for 600 s to 108 % U_n . Disconnection should not occur.

NOTE This test serves to verify the measuring accuracy.

- c) The voltage is set to 106 % U_n and maintained for 600 s. The voltage is then set to 114 % U_n . Disconnection must be effected within 300 seconds.

In the pictures below are offered graphically the results of the test.





4.4 FREQUENCY MONITORING


According to article 4.4 the NS protection should disconnect the power generation system from the net in the event of inadmissible frequency values.

The requirement from Enedis-PRO-RES_10E:26/06/2020 have been consider in this section.


Disconnection time measured					
Protective function	Frequency changes	Disconnection time limits	Test 1	Test 2	Test 3
Frequency increase protection (f>)	50.00 Hz to 51.48 Hz to 51.55 Hz	< 200 ms	105 ms	108 ms	86 ms
Frequency decrease protection (f<)	50.00Hz to 47.53Hz to 47.45 Hz	< 200 ms	96 ms	92 ms	99 ms

In the picture below are offered waveforms and graphically the results of the test.



Overfrequency 51.5 Hz- Test 1





M505104 Fri February 02 18:12:21 2024





Overfrequency 51.5 Hz- Test 2





Overfrequency 51.5 Hz- Test 3





Underfrequency 47.5 Hz- Test 1



Underfrequency 47.5 Hz- Test 2



Underfrequency 47.5 Hz- Test 3




4.5 DC CURRENT MONITORING

The verification of the protection against DC component emission test has been measured according to the standard, at the required active power levels.

The inverter has an isolation transformer, so this test item is not applicable.

4.6 ANTI ISLANDING PROTECTION

This test has been performed according to the point 6.5.3 of VDE-AR-N 4105:2011-08 and the paragraph 5.4.6 of VDE V 0124-100:2012-07.



All the tests and checks have been performed in accordance with the reference Standard as specified previously. The used quality factor of resonant load was $Q_f=2$.

There are required three different tests:


Test A is at full power

Test B is at 50%P_n

Test C is at 20%P_n


4.6.1 Test A

Balanced Load		Disconnection (ms) (limit at t=5s)
M (%)	N (%)	
0	-5	125
0	-4	156
0	-3	158
0	-2	126
0	-1	151
0	0	119
0	1	119
0	2	106
0	3	108
0	4	129
0	5	122




Test A(50Hz)

M(%)=0 & N(%)=0




Test A(50Hz)

M(%)=0 & N(%)=+1




Test A(50Hz)

M(%)=0 & N(%)=+2




Test A(50Hz)

M(%)=0 & N(%)=+3




Test A(50Hz)

M(%)=0 & N(%)=+4




Test A(50Hz)

M(%)=0 & N(%)=+5




Test A(50Hz)

M(%)=0 & N(%)=-1




Test A(50Hz)

M(%)=0 & N(%)=-2




Test A(50Hz)

M(%)=0 & N(%)=-3




Test A(50Hz)

M(%)=0 & N(%)=-4




Test A(50Hz)

M(%)=0 & N(%)=-5




4.6.2 Test B

Balanced Load		
M (%)	N (%)	Disconnection (ms) (limit at t=5s)
0	-5	124
0	-4	157
0	-3	164
0	-2	104
0	-1	194
0	0	202
0	1	155
0	2	149
0	3	159
0	4	163
0	5	105




Test B(50Hz)

M(%)=0 & N(%)=0




Test B(50Hz)

M(%)=0 & N(%)=+1




Test B(50Hz)

M(%)=0 & N(%)=+2




Test B(50Hz)

M(%)=0 & N(%)=+3




Test B(50Hz)

M(%)=0 & N(%)=+4




Test B(50Hz)

M(%)=0 & N(%)=+5




Test B(50Hz)

M(%)=0 & N(%)=-1




Test B(50Hz)

M(%)=0 & N(%)=-2




Test B(50Hz)

M(%)=0 & N(%)=-3




Test B(50Hz)

M(%)=0 & N(%)=-4




Test B(50Hz)

M(%)=0 & N(%)=-5




4.6.3 Test C


Balanced Load		
M (%)	N (%)	Disconnection (ms) (limit at t=5s)
0	-5	133
0	-4	266
0	-3	378
0	-2	181
0	-1	188
0	0	1276
0	1	280
0	2	300
0	3	122
0	4	475
0	5	382



Test C(50Hz) M(%)=0 & N(%)=0




Test C(50Hz) M(%)=0 & N(%)=+1




Test C(50Hz)

M(%)=0 & N(%)=+2




Test C(50Hz)

M(%)=0 & N(%)=+3




Test C(50Hz)

M(%)=0 & N(%)=+4




Test C(50Hz)


M(%)=0 & N(%)=+5



Test C(50Hz) M(%)=0 & N(%)=-1




Test C(50Hz) M(%)=0 & N(%)=-2




Test C(50Hz)

M(%)=0 & N(%)=-3




Test C(50Hz)

M(%)=0 & N(%)=-4



Test C(50Hz)

M(%)=0 & N(%)=-5



4.7 MARKING

As it can be seen in the pictures below (chapter 5 in this report) and the picture of the rating plate on 2.2 of this report the inverter accomplish all the requirements in this point of the VDE V 0126-1-1.

4.8 RESIDUAL CURRENT

This test has been done according to the standard EN 62109-2:2011, 4.8.3

The compliances with these requirements are stated in the following test reports:

- IEC 62109-2:2010: Test Report n° GZES231202137902 on Dec. 18, 2023 which issued by SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou Branch.

4.9 TABLE: ACTIVE POEWR OUTPUT FEED-IN AT OVERFREQUENCY

VFR 2013: Above 50,4Hz the inverter must start de-rating with 40% per Hz based on the output power at the point, when the inverter reached 50.4Hz (~51.5Hz).


VFR 2014: Above 50,6Hz the inverter must start de-rating with 40% per Hz based on the output power at the point, when the inverter reached 50.6Hz (~51.5Hz).

If the grid frequency decreases, the inverter is allowed to increase the output power in the same rate as the decreasing happened before.

String	1	U _{DC} = U _n	45Vdc	U _{ac} = U _n	230 Vac	P = P _n = (W)	800 W
U _{dc} (Vdc)	F (Hz)		F (Hz)	P (W)	time		
45	a) 50Hz (± 0.01Hz)		50.00	802	1 min		
45	b) 50.45Hz (± 0.05Hz)		50.45	781	1 min		
45	c) 50.7Hz (± 0.1Hz)		50.70	699	1 min		
45	d) 51.15Hz (± 0.05Hz)		51.15	560	1 min		
45	e) 50.75Hz (± 0.10Hz)		50.70	706	1 min		
45	f) 50.45Hz (± 0.05Hz)		50.45	781	1 min		
45	g) 50Hz (± 0.01Hz)		50.00	800	10 mins		
45	h) 51.65Hz (± 0.05Hz)		51.65	0	1 min		
45	i) 50Hz (+0.06 ~ +0.1Hz)		50.10	0	3mins		
45	j) 50Hz (± 0.01Hz)		50.00	800	10 mins		

Supplementary information:


See test curve as following



String	2	U _{DC} = Un	45Vdc	U _{ac} = Un	230 Vac	P =0.5 P _n = (W)	400 W
U _{dc} (Vdc)	F (Hz)		F (Hz)	P (W)	time		
45	a) 50Hz (± 0.01Hz)		50.00	403	1 min		
45	b) 50.45Hz (± 0.05Hz)		50.45	391	1 min		
45	c) 50.7Hz (± 0.1Hz)		50.70	350	1 min		
45	d) 51.15Hz (± 0.05Hz)		51.15	281	1 min		
45	e) 50.75Hz (± 0.10Hz)		50.70	350	1 min		
45	f) 50.45Hz (± 0.05Hz)		50.45	391	1 min		
45	g) 50Hz (± 0.01Hz)		50.00	404	10 mins		
45	h) 51.65Hz (± 0.05Hz)		51.65	0	1 min		
45	i) 50Hz (+0.06 ~ +0.1Hz)		50.10	0	3mins		
45	j) 50Hz (± 0.01Hz)		50.00	404	10 mins		

Supplementary information:


See test curve as following



String	1	U _{DC} = U _n	45Vdc	U _{ac} = U _n	230 Vac	P = P _n = (W)	800 W
U _{dc} (Vdc)	F (Hz)		F (Hz)	P (W)	time		
45	a) 50Hz (± 0.01Hz)		50.00	801	1 min		
45	b) 50.65Hz (± 0.05Hz)		50.65	780	1 min		
45	c) 50.7Hz (± 0.1Hz)		50.70	762	1 min		
45	d) 51.15Hz (± 0.05Hz)		51.15	621	1 min		
45	e) 50.75Hz (± 0.10Hz)		50.70	761	1 min		
45	f) 50.65Hz (± 0.05Hz)		50.65	781	1 min		
45	g) 50Hz (± 0.01Hz)		50.00	800	10 mins		
45	h) 51.65Hz (± 0.05Hz)		51.65	0	1 min		
45	i) 50Hz (+0.06 ~ +0.1Hz)		50.10	0	3 mins		
45	j) 50Hz (± 0.01Hz)		50.00	800	10 mins		

Supplementary information:


See test curve as following



String	2	U _{DC} = U _n	45Vdc	U _{ac} = U _n	230 Vac	P =0.5 P _n = (W)	400 W
U _{dc} (Vdc)	F (Hz)		F (Hz)	P (W)	time		
45	a) 50Hz (± 0.01Hz)		50.00	404	1 min		
45	b) 50.65Hz (± 0.05Hz)		50.65	390	1 min		
45	c) 50.7Hz (± 0.1Hz)		50.70	382	1 min		
45	d) 51.15Hz (± 0.05Hz)		51.15	308	1 min		
45	e) 50.75Hz (± 0.10Hz)		50.70	382	1 min		
45	f) 50.65Hz (± 0.05Hz)		50.65	390	1 min		
45	g) 50Hz (± 0.01Hz)		50.00	404	10 mins		
45	h) 51.65Hz (± 0.05Hz)		51.65	0	1 min		
45	i) 50Hz (+0.06 ~ +0.1Hz)		50.10	0	3 mins		
45	j) 50Hz (± 0.01Hz)		50.00	404	10 mins		

Supplementary information:

See test curve as following



5 PICTURES

Front view for model ID800D, ID600D, ID400D



Back view for model ID800D, ID600D, ID400D



Front view for model ID800M, ID600M, ID400M**Back view for model ID800M, ID600M, ID400M**

Front view for model ID800A, ID600A, ID400A



Back view for model ID800A, ID600A, ID400A



Internal view of appearance




Front view of main board



Back view of main board




After gluing



Serial Number**Software Version**

DH01.001-000-000

6 ELECTRICAL SCHEMES



-----END OF REPORT-----